

PUBLIC NOTICE

The Texas Commission on Environmental Quality (TCEQ) has notified the G&W WSC (PWS 0930048) that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for combined radium (-226 & -228). The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for combined radium (-226 & -228) to be 5 pico curies per liter (pCi/L) based on the running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for combined radium (-226 & -228) indicates a compliance value in quarter one 2024 of 8 pCi/L for EP002. (13577 CR 446 Well #6).

This is not an emergency. However, some people who drink water containing radium 226 and/or 228 in excess of the MCL over many years *may have* an increased risk of getting cancer.

You *do not* need to use an alternative water supply. However, if you have health concerns, you may want to consult your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We are still flushing and blending the above well site. The levels are going down, although it will take several quarters for it to reach below the 5 pico curies. These results are determined by adding four (4) quarterly results together then dividing by 4. With every new quarter, the oldest is quarter is removed.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: James Engledow

Area Code + Phone Number: 936-372-9858

Posted/ Delivered on: November 22, 2024

PUBLIC NOTICE

The Texas Commission on Environmental Quality (TCEQ) has notified the G&W WSC (PWS 0930048) that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for gross alpha excluding radon and uranium. The U.S. Environmental Protection Agency (U.S.EPA) has established the MCL for gross alpha excluding radon and uranium to be 15 pico curies per liter (pCi/L) based on the running annual average (RAA) and has determined that is a health concern at levels above the MCL. Analysis of drinking water in your community for gross alpha excluding radon and uranium indicates a compliance value in quarter one 2024 of 27 pCi/L for EP002 (13577 CR 446 Well #6).

This *is not* an emergency. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years *may have* an increased risk of getting cancer.

You *do not* need to use an alternative water supply. However, if you have any health concerns, you may want to consult your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We are still flushing and blending the above wellsite. These levels are also going down, although it will take several quarters for it to reach below 15 pico curies. These results are also determined by adding four (4) quarterly results together then deviding by 4. With every new quarter, the oldest quarter is removed.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact:

Water System Official: James Engledow

Area Code + Phone Number: 936-372-9858

Posted/ Delivered on: November 22, 2024